

What are Per- and Polyfluoroalkyl Substances (PFAS)?
Per and polyfluoroalkyl substances (PFAS) are a class of man-made chemicals used in common product applications such as waterproof and stain proof fabrics, nontoxic cookware, some food packaging materials and fire suppression foam. The PFAS chemicals have been manufactured and used by a broad range of industries since the 1940s due to their unique physical properties such as resistance to high and low temperatures, resistance to degradation and nonstick characteristics. PFAS chemicals have been detected worldwide in the air, soil and water.

Are Per- and Polyfluoroalkyl Substances (PFAS) in my drinking water?
PFAS have been found in drinking water and in some cases our treated drinking water. The concentrations of these compounds are very low and expressed in parts per trillion, which is equivalent to one single drop of water in twenty-olympic-sized swimming pools.

PFAS Limits in Drinking Water Update:
On April 10, 2024, EPA announced the final drinking water standards or Maximum Contaminant Limits (MCLs) to limit six PFAS compounds in drinking water. Those limits are as follows: PFOA - 4 ppt (ng/L), PFOS - 4 ppt (ng/L), GenX chemicals (HFO-DA) - 10 ppt (ng/L), PFNA - 10 ppt (ng/L), PFHxS - 10 ppt (ng/L) and the rule also regulates mixtures of GenX chemicals, PFNA, PFHxS and PFBS through the use of a Hazard Index calculation to determine if the combined levels of these PFAS pose a potential risk to human health. Public water systems such as the Graham-Bleed Water Plant will have five years to meet the new standard.

How is the City of Graham moving toward meeting the new regulations for PFAS?
The City of Graham is currently undergoing engineering study of enhanced treatment options in order to be prepared to meet the new regulations by the 2029 deadline. The City of Graham's Water Plant staff will continue to be vigilant in staying informed of all the new regulations for the PFAS chemicals and will strive to meet all requirements that are forth coming.

		PFAS RESULTS (ng/L)																													
Sample Matrix	Sample Collection Date	PFBA	PFPeA	PFHxA	PFHpA	PFOA	PFNA	PFDA	PFUnA	PFDoA	ADONA	PFBS	PFHxS	PFHpS	PFOS	PFPeS	HFPO-DA	9CI-PF3ONS	11CI-PF3OUs	4:2 FTS	6:2 FTS	8:2 FTS	NFHA	PFMPA	PFMBA	PFESA	NeFOSAA	NMeFOSAA	PFTA	PFTyDA	
Distribution Water @ Entry Point	11/13/2023	<MRL	3.4	3.5	<MRL	7.6	<MRL	<MRL	<MRL	<MRL	<MRL	10.6	<MRL	<MRL	7.4	<MRL	<MRL	<MRL	<MRL	<MRL	<MRL	<MRL	<MRL	<MRL	<MRL	<MRL	<MRL	<MRL	<MRL	<MRL	
Raw Water	1/13/2024	2.9	ND	ND	ND	3.5	ND	ND	ND	ND	ND	6.0	ND	ND	4.2	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	
Finished Water	1/13/2024	1.8	ND	ND	ND	2.8	ND	ND	ND	ND	ND	3.9	ND	ND	2.9	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	
Distribution Water @ Entry Point	2/13/2024																											<MRL	<MRL	<MRL	<MRL
Distribution Water @ Entry Point	3/13/2024	<MRL	<MRL	<MRL	<MRL	4.2	<MRL	<MRL	<MRL	<MRL	<MRL	6.4	<MRL	<MRL	4.3	<MRL	<MRL	<MRL	<MRL	<MRL	<MRL	<MRL	<MRL	<MRL	<MRL	<MRL	<MRL				
Raw Water	3/28/2024	<MRL	<MRL	<MRL	<MRL	3.55	<MRL	<MRL	<MRL	<MRL	<MRL	<MRL	<MRL	<MRL	<MRL	<MRL	<MRL	<MRL	<MRL	<MRL	<MRL	<MRL	<MRL	<MRL	<MRL	<MRL	<MRL				
Raw Water	4/25/2024	<MRL	<MRL	<MRL	<MRL	4.04	<MRL	<MRL	<MRL	<MRL	<MRL	5.96	<MRL	<MRL	4.29	<MRL	<MRL	<MRL	<MRL	<MRL	<MRL	<MRL	<MRL	<MRL	<MRL	<MRL	<MRL				
Distribution Water @ Entry Point	5/13/2024	<MRL	<MRL	<MRL	<MRL	5.0	<MRL	<MRL	<MRL	<MRL	<MRL	7.1	<MRL	<MRL	5.2	<MRL	<MRL	<MRL	<MRL	<MRL	<MRL	<MRL	<MRL	<MRL	<MRL	<MRL	<MRL	<MRL	<MRL	<MRL	<MRL
Distribution Water @ Entry Point	8/12/2024	<MRL	<MRL	<MRL	<MRL	4.0	<MRL	<MRL	<MRL	<MRL	<MRL	6.6	<MRL	<MRL	4.8	<MRL	<MRL	<MRL	<MRL	<MRL	<MRL	<MRL	<MRL	<MRL	<MRL	<MRL	<MRL	<MRL	<MRL	<MRL	<MRL
Raw Water	9/3/2024	<MRL	<MRL	<MRL	<MRL	6.22	<MRL	<MRL	<MRL	<MRL	<MRL	<MRL	<MRL	<MRL	<MRL	<MRL	<MRL	<MRL	<MRL	<MRL	<MRL	<MRL	<MRL	<MRL	<MRL	<MRL					

MRL - Minimum Reporting Limit ND - Non Detect
 Samples analyzed by a commercial laboratory by the EPA 533 Method unless otherwise noted.
 NEtFOSAA, NMeFOSAA, PFTA and PFTdA analyzed by a commercial laboratory by the EPA 537.1 Method.
 PFOA analyzed by a commercial laboratory by Isotope Dilution Method (BLT).